

Add: 4N Donghai Int'l Building, No.17 Huiquan Road, Qingdao, China

## MILL TEST CERTIFICATE

**Customer:** PRODALAM S.A.  
**Commodity:** PRESTRESSED CONCRETE STRAND  
**Nominal Diameter:** 15.24 MM  
**Standard:** ASTM A416/A416M-15  
**Production Liscence No:** XK 05-003-00098  
**Page No:** 2/8  
**Inspection Date:** FEB,23, 2024  
**Invoice No:** PCLPID2401C  
**Container No.** BEAU2268582



Mark on Coil	Coil No.	Dia MM	Section Area (mm <sup>2</sup> )	Breaking Load (kN)	Tensile Strength MPA	1%Extension Yield Load (kN)	Yield Strength MPA	Elongation (%)	Modules of Elasticity GPA	Length Approx. Meter	Coil Weight KGS
C10	2402109-1	15.24	140.76	272.2	1944	253.9	1814	5.0	198.0	2308	2576
C10	2402109-4	15.24	140.76	271.7	1941	246.5	1761	4.7	194.1	2393	2670
C10	2402109-5	15.24	140.76	272.0	1943	247.8	1770	5.0	198.0	2586	2884
C10	2402316-1	15.31	141.91	273.5	1954	253.5	1811	5.1	190.9	3079	3432
C10	2402316-2	15.31	141.91	273.0	1950	251.9	1799	5.0	194.4	2870	3200
C10	2402316-3	15.31	141.91	272.7	1948	252.6	1804	4.8	193.0	2870	3200
C10	2402316-4	15.31	141.91	272.2	1944	253.8	1813	4.8	196.7	2870	3200
C10	2402316-5	15.31	141.91	272.0	1943	251.4	1796	4.9	191.4	2870	3200
C10	2402112-6	15.31	141.91	273.4	1953	250.7	1791	5.0	197.5	2986	3328

Quality objection: The buyer shall notify the seller in writing by email of any non-conformity of the quantity or quality of the subject matter within three months after arrival at the port. Where the buyer delays in giving notice beyond the prescribed time limit, the quantity or quality of the subject matter is deemed to be in conformity with the contract.

**Filled by :Zhangchunting**

**Approved by : Shenyingsiang**