




## MILL TEST CERTIFICATE

**Customer:** PRODALAM S.A.  
**Commodity:** PRESTRESSED CONCRETE STRAND  
**Nominal Diameter:** 15.24MM  
**Standard:** ASTM A416/A416M-15  
**Production Licence No:** XK 05-003-00098  
**Page No:** 1/8  
**Inspection Date:** MAR.5th,2023  
**Invoice No:** PCLPID2302C  
**Container No.** CMAU0234786



Mark on Coil	Coil No.	Dia MM	Section Area (mm <sup>2</sup> )	Breaking Load (kN)	Tensile Strength MPA	1%Extension Yield Load (kN)	Yield Strength MPA	Elongation (%)	Modules of Elasticity GPA	Length Approx. Meter	Coil Weight KGS
J2	2302177-1	15.30	141.02	271.0	1936	251.0	1793	5.0	199.5	2453	2732
J2	2302394-2	15.26	140.64	271.0	1936	249.0	1779	5.5	195.3	2832	3152
J2	2302394-3	15.26	140.64	269.8	1927	251.0	1793	5.5	193.8	2832	3152
J2	2302394-4	15.26	140.64	268.8	1920	250.3	1788	5.4	191.7	2834	3154
J2	2302394-5	15.26	140.64	269.5	1925	253.7	1812	5.5	197.3	2836	3156
J2	2302395-3	15.28	140.89	268.7	1919	248.1	1772	5.0	193.6	2847	3168
J2	2302395-4	15.28	140.89	270.3	1931	252.7	1805	5.3	196.1	2847	3168
J2	2302398-6	15.23	140.51	269.2	1923	250.8	1791	5.4	195.6	2935	3266
J2	2302183-1	15.26	140.89	270.4	1931	254.2	1816	5.1	191.7	2451	2730

Filed by :Zhangchunting

Approved by : Shenyingsiang