



# QINGDAO GLOBAL OVERSEAS IMP&EXP CO., LTD

Add: 4N Donghai Int'l Building, No.17 Huiquan Road, Qingdao, China

## MILL TEST CERTIFICATE

**Customer:** PRODALAM S.A.  
**Commodity:** PRESTRESSED CONCRETE STRAND  
**Nominal Diameter:** 15.24MM  
**Standard:** ASTM A416/A416M-15  
**Production Licence No:** XK 05-003-00098  
**Page No:** 8/8  
**Inspection Date:** OCT.06, 2022  
**Invoice No:** PCLPY2202C  
**Container No.** ECMU2109770



Mark on Coil	Coil No.	Dia MM	Section Area (mm <sup>2</sup> )	Breaking Load (kN)	Tensile Strength MPA	1%Extension Yield Load (kN)	Yield Strength MPA	Elongation (%)	Modules of Elasticity GPA	Length Approx. Meter	Coil Weight KGS
B8	2210113-4	15.34	142.04	278.9	1992	255.3	1824	5.0	192.5	2458	2742
B8	2210113-5	15.34	142.04	278.7	1991	255.1	1822	4.9	192.7	2656	2962
B8	2210114-1	15.35	141.91	277.6	1983	261.5	1868	5.2	199.5	3068	3420
B8	2210114-5	15.33	141.91	277.5	1982	254.0	1814	5.1	198.7	2863	3192
B8	2210319-2	15.30	141.40	274.5	1961	254.4	1817	5.3	196.3	2461	2746
B8	2210319-3	15.30	141.40	275.7	1969	254.2	1816	5.2	196.1	2461	2746
B8	2210319-4	15.30	141.40	275.2	1966	250.2	1787	5.3	191.0	3068	3420
B8	2210320-2	15.28	141.15	274.8	1963	254.4	1817	5.0	198.0	3056	3406
B8	2210320-5	15.28	141.15	274.4	1963	247.9	1771	5.2	191.7	2449	2732

Filed by :Zhangchunting

Approved by : Shenyingsiang