

MILL TEST CERTIFICATE

Customer: PRODALAM S.A.
Commodity: PRESTRESSED CONCRETE STRAND
Nominal Diameter: 15.24 MM
Standard: ASTM A416/A416M-15
Production Licence No: XK 05-003-00098
Page No: 5/6
Inspection Date: JAN. 10TH, 2025
Invoice No: PCLPID2405C
Container No. MSBU1232132

Mark on Coil	Coil No.	Dia MM	Section Area (mm ²)	Breaking Load (kN)	Tensile Strength MPA	1%Extension Yield Load (kN)	Yield Strength MPA	Elongation (%)	Modules of Elasticity GPA	Length Approx. Meter	Coil Weight KGS
Q12	2412121-7	15.26	140.89	275.0	1964	248.4	1774	5.0	196.8	1928	2154
Q12	2412361-6	15.27	141.15	271.2	1937	245.6	1754	5.0	195.2	2849	3176
Q12	2412362-2	15.28	141.27	272.2	1944	251.4	1796	5.3	198.2	2850	3178
Q12	2412362-3	15.28	141.27	271.8	1941	250.2	1787	5.2	199.2	2849	3176
Q12	2412362-4	15.28	141.27	271.4	1939	250.5	1789	5.1	196.8	2850	3178
Q12	2412362-5	15.28	141.27	272.6	1947	249.8	1784	5.4	197.2	2849	3176
Q12	2412363-2	15.27	141.15	269.4	1924	248.6	1776	5.2	196.2	2843	3170
Q12	2412363-3	15.27	141.15	272.4	1946	244.3	1745	5.4	197.4	2843	3170
Q12	2412373-4	15.27	140.89	271.5	1939	249.1	1779	4.8	195.9	3038	3386

Quality objection: The buyer shall notify the seller in writing by email of any non-conformity of the quantity or quality of the subject matter within three months after arrival at the port. Where the buyer delays in giving notice beyond the prescribed time limit, the quantity or quality of the subject matter is deemed to be in conformity with the contract.

Filled by :Zhangchunting

Approved by : Shenyingsiang