



MILL TEST CERTIFICATE

Customer: PRODALAM S.A.
Commodity: PRESTRESSED CONCRETE STRAND
Nominal Diameter: 15.24MM
Standard: ASTM A416/A416M-15
Production Lisence No: XK 05-003-00098
Page No: 5/12
Inspection Date: OCT.21, 2022
Invoice No: PCLPY2203C
Container No. CAIU2517463



Mark on Coil	Coil No.	Dia MM	Section Area (mm ²)	Breaking Load (kN)	Tensile Strength MPA	1%Extension Yield Load (kN)	Yield Strength MPA	Elongation (%)	Modules of Elasticity GPA	Length Approx. Meter	Coil Weight KGS
J5	2210388-4	15.26	140.76	272.8	1949	257.2	1837	4.5	193.3	2845	3166
J5	2210388-5	15.26	140.76	271.4	1939	256.4	1831	5.2	193.7	2847	3168
J5	2210388-6	15.26	140.76	270.4	1931	253.6	1811	5.5	197.1	2845	3166
J5	2210389-6	15.28	141.53	274.1	1958	252.0	1800	6.0	193.6	2823	3142
J5	2210523-3	15.24	140.76	274.0	1957	251.4	1796	5.6	198.1	2437	2714
J5	2210523-7	15.24	140.76	272.6	1947	253.4	1810	5.6	193.7	2404	2678
J5	2210524-7	15.24	140.89	272.0	1943	253.6	1811	6.0	198.8	2690	2994
J5	2210526-4	15.28	141.02	275.8	1970	256.2	1830	5.0	196.4	2838	3158
J5	2210528-3	15.25	141.02	272.2	1944	252.3	1802	5.2	198.2	2789	3104

Filed by :Zhangchunting

Approved by : Shenyingsiang