




MILL TEST CERTIFICATE

Customer: PRODALAM S.A.
Commodity: PRESTRESSED CONCRETE STRAND
Nominal Diameter: 15.24MM
Standard: ASTM A416/A416M-15
Production Liscence No: XK 05-003-00098
Page No: 2/14
Inspection Date: FEB.5th,2022
Invoice No: PCLPY2301C
Container No. CAIU3606360



Mark on Coil	Coil No.	Dia MM	Section Area (mm ²)	Breaking Load (kN)	Tensile Strength MPA	1%Extension Yield Load (kN)	Yield Strength MPA	Elongation (%)	Modules of Elasticity GPA	Length Approx. Meter	Coil Weight KGS
B4	2302502-3	15.25	140.76	270.9	1935	250.5	1789	4.8	197.1	2856	3178
B4	2302502-4	15.25	140.76	271.4	1939	248.4	1774	4.9	197.0	2830	3150
B4	2302502-5	15.25	140.76	271.0	1936	248.6	1776	4.8	194.8	2843	3164
B4	2302502-6	15.25	140.76	271.2	1937	249.5	1782	5.2	191.9	2834	3154
B4	2302503-1	15.25	140.64	273.1	1951	249.8	1784	4.5	197.5	2832	3152
B4	2302504-3	15.24	140.51	272.6	1947	252.6	1804	5.0	196.9	3034	3376
B4	2301343-2	15.34	141.91	271.4	1939	248.8	1777	5.2	195.3	2473	2754
B4	2301343-3	15.34	141.91	272.1	1944	251.0	1793	5.0	198.0	2473	2754
B4	2302308-7	15.28	141.02	271.2	1937	250.4	1789	5.2	193.9	2769	3082

Filed by :Zhangchunting

Approved by : Shenyingsiang