



MILL TEST CERTIFICATE

Customer: PRODALAM S.A.
Commodity: PRESTRESSED CONCRETE STRAND
Nominal Diameter: 15.24MM
Standard: ASTM A416/A416M-15
Production Licence No: XK 05-003-00098
Page No: 1/12
Inspection Date: OCT.21, 2022
Invoice No: PCLPY2203C
Container No. TCLU3690823



Mark on Coil	Coil No.	Dia MM	Section Area (mm ²)	Breaking Load (kN)	Tensile Strength MPA	1%Extension Yield Load (kN)	Yield Strength MPA	Elongation (%)	Modules of Elasticity GPA	Length Approx. Meter	Coil Weight KGS
J1	2210382-6	15.26	140.51	273.0	1950	249.2	1780	5.1	196.1	2814	3132
J1	2210383-1	15.25	140.38	270.1	1929	253.1	1808	5.1	194.3	3027	3368
J1	2210383-2	15.25	140.38	270.2	1930	251.6	1797	5.2	192.1	2834	3154
J1	2210383-4	15.25	140.38	270.6	1933	248.3	1774	5.3	194.3	2635	2934
J1	2210383-6	15.25	140.38	270.2	1930	249.6	1783	5.4	198.4	2706	3012
J1	2210384-1	15.25	140.64	272.3	1945	247.9	1771	5.8	198.9	2446	2724
J1	2210384-2	15.25	140.64	273.0	1950	247.7	1769	5.5	198.7	2446	2724
J1	2210385-7	15.24	140.64	270.0	1929	250.4	1789	5.1	194.7	2693	2998
J1	2210526-3	15.28	141.02	274.8	1963	252.1	1801	5.5	198.8	2834	3154

Filed by :Zhangchunting

Approved by : Shenyingsiang