



QINGDAO GLOBAL OVERSEAS IMP&EXP CO., LTD

Add: 4N Donghai Int'l Building, No.17 Huiquan Road, Qingdao, China

MILL TEST CERTIFICATE

Customer: PRODALAM S.A.
Commodity: PRESTRESSED CONCRETE STRAND
Nominal Diameter: 15.24MM
Standard: ASTM A416/A416M-15
Production Licence No: XK 05-003-00098
Page No: 2/8
Inspection Date: OCT.06, 2022
Invoice No: PCLPY2202C
Container No. DFSU2058915



Mark on Coil	Coil No.	Dia MM	Section Area (mm ²)	Breaking Load (kN)	Tensile Strength MPA	1%Extension Yield Load (kN)	Yield Strength MPA	Elongation (%)	Modules of Elasticity GPA	Length Approx. Meter	Coil Weight KGS
B2	2210302-2	15.31	141.40	276.8	1977	250.7	1791	5.3	194.0	2856	3184
B2	2210302-3	15.31	141.40	275.9	1971	250.6	1790	5.2	192.6	2856	3184
B2	2210305-5	15.31	141.53	274.0	1957	252.7	1805	5.5	198.1	2859	3188
B2	2210306-1	15.34	142.04	276.5	1975	250.3	1788	5.6	194.6	2468	2754
B2	2210306-2	15.34	142.04	274.8	1963	252.7	1805	5.6	196.7	2472	2758
B2	2210306-3	15.34	142.04	275.1	1965	253.6	1811	5.5	197.2	2468	2754
B2	2210306-4	15.34	142.04	276.2	1973	253.7	1812	5.2	195.5	2468	2754
B2	2210307-1	15.30	141.40	274.1	1958	258.8	1849	5.0	194.4	3058	3408
B2	2210308-4	15.32	141.53	275.7	1969	249.4	1781	5.4	191.5	3074	3426

Filed by :Zhangchunting

Approved by : Shenyangxiang