



**QINGDAO GLOBAL OVERSEAS IMP&EXP CO., LTD**

Add: 4N Donghai Int'l Building, No.17 Huiquan Road, Qingdao, China

**MILL TEST CERTIFICATE**

**Customer:** PRODALAM S.A.  
**Commodity:** PRESTRESSED CONCRETE STRAND  
**Nominal Diameter:** 15.24MM  
**Standard:** ASTM A416/A416M-15  
**Production Liscence No:** XK 05-003-00098  
**Page No:** 7/8  
**Inspection Date:** OCT.06, 2022  
**Invoice No:** PCLPY2202C  
**Container No.** ECMU1670072



Mark on Coil	Coil No.	Dia MM	Section Area (mm <sup>2</sup> )	Breaking Load (kN)	Tensile Strength MPA	1%Extension Yield Load (kN)	Yield Strength MPA	Elongation (%)	Modules of Elasticity GPA	Length Approx. Meter	Coil Weight KGS
B7	2210112-2	15.34	142.04	279.6	1997	260.2	1859	5.0	198.7	2856	3184
B7	2210112-3	15.34	142.04	279.8	1999	260.0	1857	4.9	198.9	2858	3186
B7	2210112-5	15.34	142.04	279.5	1996	254.6	1819	5.0	199.2	2858	3186
B7	2210113-2	15.34	142.04	280.5	2004	264.7	1891	4.8	199.3	2436	2718
B7	2210113-3	15.34	142.04	280.3	2002	264.5	1889	4.7	199.1	2434	2716
B7	2210113-6	15.34	142.04	278.5	1989	254.9	1821	4.8	192.9	2459	2744
B7	2210114-2	15.33	141.91	277.4	1981	261.3	1866	5.1	199.3	2863	3192
B7	2210114-3	15.33	141.91	277.2	1980	261.1	1865	4.9	199.1	2865	3194
B7	2210114-4	15.33	141.91	277.7	1980	254.2	1816	5.0	198.5	2867	3196

**Filed by :Zhangchunting**

**Approved by : Shenyingxiang**