



QINGDAO GLOBAL OVERSEAS IMP&EXP CO., LTD

Add: 4N Donghai Int'l Building, No.17 Huiquan Road, Qingdao, China

MILL TEST CERTIFICATE

Customer:

PRODALAM S.A.

Commodity:

PRESTRESSED CONCRETE STRAND

Nominal Diameter:

15.24MM

Standard:

ASTM A416/A416M-15

Production Liscence No:

XK 05-003-00098

Page No:

3/4

Inspection Date:

MAR.28TH,2023

Invoice No:

PCLPID2304C-1

Container No.

TLLU2341471



Mark on Coil	Coil No.	Dia MM	Section Area (mm ²)	Breaking Load (kN)	Tensile Strength MPA	1%Extension Yield Load (kN)	Yield Strength MPA	Elongation (%)	Modules of Elasticity GPA	Length Approx. Meter	Coil Weight KGS
B10	2303398-5	15.28	141.40	273.1	1951	251.7	1798	5.2	195.0	2450	2734
B10	2303403-6	15.32	142.42	271.5	1939	250.3	1788	5.2	198.1	2948	3286
B10	2303404-5	15.25	140.89	269.3	1924	246.5	1761	5.2	195.2	3023	3370
B10	2303404-6	15.25	140.89	270.8	1934	247.7	1769	5.3	198.4	2962	3302
B10	2303406-5	15.29	141.53	273.2	1951	249.7	1784	4.7	198.8	2863	3192
B10	2303406-6	15.29	141.53	274.1	1958	250.4	1789	5.0	199.3	2968	3308
B10	2303411-5	15.29	141.27	269.8	1927	248.2	1773	5.2	193.2	2443	2726
B10	2303411-6	15.29	141.27	270.1	1929	249.5	1782	5.2	196.1	2445	2728
B10	2303411-7	15.29	141.27	269.6	1926	250.6	1790	5.1	197.5	2694	3004

Filled by :Zhangchunting

Approved by : Shenyingxiang