




MILL TEST CERTIFICATE

Customer: PRODALAM S.A.
Commodity: PRESTRESSED CONCRETE STRAND
Nominal Diameter: 15.24MM
Standard: ASTM A416/A416M-15
Production Licence No: XK 05-003-00098
Page No: 8/12
Inspection Date: Jan.4th,2022
Invoice No: PCLPY2205C
Container No. APZU3438140



Mark on Coil	Coil No.	Dia MM	Section Area (mm ²)	Breaking Load (kN)	Tensile Strength MPA	1%Extension Yield Load (kN)	Yield Strength MPA	Elongation (%)	Modules of Elasticity GPA	Length Approx. Meter	Coil Weight KGS
C8	2212381-7	15.25	140.64	273.1	1951	251.0	1793	4.9	197.0	2722	3030
C8	2301301-5	15.25	140.51	274.2	1959	250.7	1791	4.8	196.4	2440	2718
C8	2301301-6	15.25	140.51	274.0	1957	252.4	1803	5.0	192.7	2440	2718
C8	2301103-1	15.27	141.02	277.0	1979	257.6	1840	4.7	197.8	2829	3148
C8	2301103-2	15.27	141.02	276.7	1976	254.9	1821	4.9	199.6	2829	3148
C8	2301103-3	15.27	141.02	276.5	1975	255.8	1827	5.0	197.2	3063	3408
C8	2301103-4	15.27	141.02	276.1	1972	253.8	1813	5.1	195.1	2857	3180
C8	2301103-5	15.27	141.02	276.3	1974	253.9	1814	5.2	197.2	2859	3182
C8	2301103-6	15.27	141.02	276.4	1974	254.4	1817	5.2	196.2	2944	3276

Filled by :Zhangchunting

Approved by : Shenyingsiang