

Add: 4N Donghai Int'l Building, No.17 Huiquan Road, Qingdao, China

MILL TEST CERTIFICATE

Customer: PRODALAM S.A.
Commodity: PRESTRESSED CONCRETE STRAND
Nominal Diameter: 15.24 MM
Standard: ASTM A416/A416M-18
Production Liscence No: XK 05-003-00098
Page No: 7/8
Inspection Date: Aug.21th,2023
Invoice No: PCLPID2307C
Container No. APZU3601832



Mark on Coil	Coil No.	Dia MM	Section Area (mm ²)	Breaking Load (kN)	Tensile Strength MPA	1%Extension Yield Load (kN)	Yield Strength MPA	Elongation (%)	Modules of Elasticity GPA	Length Approx. Meter	Coil Weight KGS
A17	2308149-1	15.30	141.78	271.6	1940	255.0	1821	4.7	195.7	2297	2564
A17	2308150-1	15.32	141.78	272.4	1946	256.1	1829	4.9	192.5	3074	3426
A17	2308151-5	15.32	141.91	272.0	1943	255.7	1826	5.2	192.0	2272	2536
A17	2308152-4	15.31	141.66	273.2	1951	256.2	1830	5.0	198.2	3072	3424
A17	2308152-5	15.31	141.66	273.4	1953	254.2	1816	5.1	191.6	3065	3416
A17	2308372-5	15.26	140.64	269.4	1924	247.4	1767	5.0	192.9	2297	2564
A17	2308373-4	15.25	140.89	266.8	1906	250.6	1790	4.9	191.3	2634	2938
A17	2308375-1	15.30	141.40	266.1	1901	250.6	1790	4.9	194.5	3065	3416
A17	2308376-1	15.28	141.02	266.4	1903	248.5	1775	4.9	197.0	3047	3396

Quality objection: The buyer shall notify the seller in writing by email of any non-conformity of the quantity or quality of the subject matter within three months after arrival at the port. Where the buyer delays in giving notice beyond the prescribed time limit, the quantity or quality of the subject matter is deemed to be in conformity with the contract.

Filled by :Zhangchunting

Approved by : Shenyingsiang