



MILL TEST CERTIFICATE

Customer: PRODALAM S.A.
Commodity: PRESTRESSED CONCRETE STRAND
Nominal Diameter: 15.24MM
Standard: ASTM A416/A416M-15
Production Licence No: XK 05-003-00098
Page No: 6/14
Inspection Date: FEB.5th,2022
Invoice No: PCLPY2301C
Container No. MEDU3483570



Mark on Coil	Coil No.	Dia MM	Section Area (mm ²)	Breaking Load (kN)	Tensile Strength MPA	1%Extension Yield Load (kN)	Yield Strength MPA	Elongation (%)	Modules of Elasticity GPA	Length Approx. Meter	Coil Weight KGS
B8	2302505-5	15.25	140.64	273.4	1953	251.7	1798	5.0	195.8	2727	3036
B8	2302506-4	15.26	140.76	272.9	1949	248.1	1772	5.5	191.6	2838	3158
B8	2302506-5	15.26	140.76	273.0	1950	251.6	1797	5.0	192.6	2838	3158
B8	2302507-6	15.26	140.64	270.8	1934	251.6	1797	5.0	193.8	2637	2936
B8	2302508-2	15.26	140.76	269.8	1927	252.1	1801	5.0	198.8	2834	3154
B8	2302508-4	15.26	140.76	270.5	1932	247.1	1765	5.1	190.5	2836	3156
B8	2302508-5	15.26	140.76	269.8	1927	251.0	1793	5.2	191.4	2836	3156
B8	2302509-2	15.26	140.64	269.8	1927	252.7	1805	5.2	195.3	2830	3150
B8	2301343-7	15.34	141.91	272.2	1944	251.0	1793	5.5	195.3	2664	2966

Filed by :Zhangchunting

Approved by : Shenyingsiang