



MILL TEST CERTIFICATE

Customer:

PRODALAM S.A.

Commodity:

PRESTRESSED CONCRETE STRAND

Nominal Diameter:

15.24MM

Standard:

ASTM A416/A416M-15

Production Lisence No:

XK 05-003-00098

Page No:

10/12

Inspection Date:

OCT.21, 2022

Invoice No:

PCLPY2203C

Container No.

CAIU2490378



Mark on Coil	Coil No.	Dia MM	Section Area (mm <sup>2</sup> )	Breaking Load (kN)	Tensile Strength MPA	1%Extension Yield Load (kN)	Yield Strength MPA	Elongation (%)	Modules of Elasticity GPA	Length Approx. Meter	Coil Weight KGS
J10	2210536-6	15.32	141.78	273.0	1950	252.7	1805	5.0	191.7	2829	3148
J10	2210398-7	15.25	140.64	273.0	1950	252.0	1800	5.5	198.1	2715	3022
J10	2210399-5	15.25	140.76	272.0	1943	250.3	1788	5.5	190.8	2446	2724
J10	2210399-6	15.25	140.76	272.3	1945	251.6	1797	6.0	193.6	2444	2722
J10	2210399-7	15.25	140.76	273.0	1950	252.6	1804	5.6	194.6	2729	3038
J10	2210400-2	15.24	140.51	272.2	1944	249.3	1781	5.0	193.8	2829	3148
J10	2210400-3	15.24	140.51	272.8	1949	251.0	1793	5.5	198.3	2827	3146
J10	2210400-4	15.24	140.51	271.2	1937	252.5	1804	5.0	193.6	2829	3148
J10	2210400-5	15.24	140.51	271.8	1941	248.3	1774	5.4	193.5	2829	3148

Filed by :Zhangchunting

Approved by : Shenyingsiang