



质量证明书

MILL TEST CERTIFICATE

日照钢铁控股集团有限公司
Rizhao Steel Holding Group Co., Ltd.
山东省日照市岚山区滨海路600号/276806
No. 600, Binhai Road, Lanshan District, Rizhao City, Shandong,
P. R. China/276806
TEL: 质保书服务 06332968271 客户监督 4001380006

订货单位 CONSIGNEE:

产品名称 PRODUCT: 热轧H型钢H Beams

发货日期 DATE OF ISSUE: 2025 年YY 11 月MM 10 日DD

合同号 CONTRACTNO.: CDS2511030039

执行标准 STANDARD: ASTM A572/A572M-21

牌号(级别代号) STEEL GRADE: A572Gr50

质保书号 MILLSHEETNO.: 251110S00070

最后客户 FINAL CUSTOMER: 2503406

交货状态 DELIVERY STATE: 热轧 Hot Rolled

品级 QUALITY CLASS: 正品 Qualified Product

S00070-1

取样号 SAMPLE NO.	炉号 HEAT NO.	规格及重量 MATERIAL DESCRIPTION				化学成份 CHEMICAL ANALYSES													A1(TL) 拉伸试验 L0=200mm			A4 屈服比 Y.T. ReL/Rm	REMARK		
						C %	Si %	Mn %	P %	S %	V %	Cu %	Cr %	Ni %	Mo %	Nb %	CEV %	Sn %	屈服 Y.S. ReL	抗拉 T.S. Rm	伸长 EL A200mm				
		x10 ⁻²	x10 ⁻²	x10 ⁻²	x10 ⁻³														x10 ⁻³	x10 ⁻³	x10 ⁻²	x10 ⁻²		x10 ⁻²	x10 ⁻³
规范范围 SPECIFICATION						23	40	160	35	45	150	60	35	45	150	50	45	2000	345	450	18	85			
HBM25B1842	W25310891H	W10×30 lbs/ft*12,000			5	40	21.52	22	31	111	21	10	3	1	2	1	2	7	41	102	427	563	24.0	76	
HBM25B1843	W25310892	W10×30 lbs/ft*12,000			1	8	4.304	21	33	116	25	11	3	0	2	1	0	7	41	12	378	542	23.5	70	
HBM25B1844	W25310892	W10×30 lbs/ft*12,000			1	8	4.304	21	33	116	25	11	3	0	2	1	0	7	41	12	427	563	24.0	76	
TOTAL:					7	56	30.128																		
注释 NOTE	CEV=C+Mn/6+(Cr+V+Mo)/5+(Cu+Ni)/15 L0=原始拉伸标距Original Gauge Length A1(TL)=Tensile Test Tail Longitudinal Sampling Y.S=Yield Strength		T.S=Tensile Strength E.L=Percentage Elongation After Fracture A4=Yield Ratio																						
备注 REMARK	表面及外形尺寸 SURFACE AND SIZE: 合格 QUALIFIED 无质量证明书专用章印记无效 INVALID WITHOUT SEAL ACCORDING TO EN 10204 3. 1																								



尊敬的客户: 用前先要验证, 如有异议请保留实物并来函说明, 邮箱zhibaoshujianding@rizhaosteel.com.
FOR CUSTOMERS: TEST BEFORE USE, CLAIM FOR DISCREPANCIES WITH DEFAULT GOODS, E-mail: zhibaoshujianding@rizhaosteel.com.

本公司已通过 ISO9001 质量管理体系认证
APPROVED BY ISO9001