



QINGDAO GLOBAL OVERSEAS IMP&EXP CO., LTD

Add: 4N Donghai Int'l Building, No.17 Huiquan Road, Qingdao, China

MILL TEST CERTIFICATE

Customer: PRODALAM S.A.
Commodity: PRESTRESSED CONCRETE STRAND
Nominal Diameter: 15.24 MM
Standard: ASTM A416/A416M-18
Production Liscence No: XK 05-003-00098
Page No: 3/8
Inspection Date: Aug.21th,2023
Invoice No: PCLPID2307C
Container No. CMAU0340535



Mark on Coil	Coil No.	Dia MM	Section Area (mm ²)	Breaking Load (kN)	Tensile Strength MPA	1%Extension Yield Load (kN)	Yield Strength MPA	Elongation (%)	Modules of Elasticity GPA	Length Approx. Meter	Coil Weight KGS
A14	2308370-6	15.28	141.27	273.4	1953	248.6	1776	4.7	197.2	2458	2742
A14	2308149-4	15.30	141.78	272.6	1947	250.7	1791	5.2	195.5	2874	3204
A14	2308374-6	15.29	141.53	268.5	1918	247.7	1769	5.2	192.8	2440	2722
A14	2308375-3	15.30	141.40	266.6	1904	248.4	1774	5.0	191.4	2858	3186
A14	2308375-4	15.30	141.40	266.8	1906	245.6	1754	5.1	191.4	2858	3186
A14	2308376-2	15.28	141.02	266.8	1906	249.2	1780	5.0	192.9	2841	3168
A14	2308376-3	15.28	141.02	266.4	1903	247.4	1767	5.1	196.5	2843	3170
A14	2308376-4	15.28	141.02	266.2	1901	244.2	1744	5.5	191.6	2841	3168
A14	2308376-5	15.28	141.02	266.3	1902	248.4	1774	5.1	197.2	2841	3168

Quality objection: The buyer shall notify the seller in writing by email of any non-conformity of the quantity or quality of the subject matter within three months after arrival at the port. Where the buyer delays in giving notice beyond the prescribed time limit, the quantity or quality of the subject matter is deemed to be in conformity with the contract.

Filled by :Zhangchunting

Approved by : Shenyingxiang