



质量证明书

MILL TEST CERTIFICATE

日照钢铁控股集团有限公司
Rizhao Steel Holding Group Co., Ltd.
山东省日照市岚山区滨海路600号/276806
No. 600, Binhai Road, Lanshan District, Rizhao City, Shandong,
P. R. China/276806
TEL: 质保书服务 06332968271 客户监督 4001380006

订货单位 CONSIGNEE:

产品名称 PRODUCT: 热轧H型钢H Beams

发货日期 DATE OF ISSUE: 2025 年YY 04 月MM 11 日DD

合同号 CONTRACTNO.: CDS2503210045

执行标准 STANDARD: ASTM A572/A572M-21

牌号(级别代号) STEEL GRADE: A572Gr50

质保书号 MILLSHEETNO.: 250411S00078

最后客户 FINAL CUSTOMER: 2503406

交货状态 DELIVERY STATE: 热轧 Hot Rolled

品级 QUALITY CLASS: 正品 Qualified Product

S00078-1

取样号 SAMPLE NO.	炉号 HEAT NO.	规格及重量 MATERIAL DESCRIPTION			化学成份 CHEMICAL ANALYSES						A1(TL) 拉伸试验 L0=200mm			REMARK
		规格mm/型号 DIMENSION	件数 QTY	重量 t WEIGHT	C	Si	Mn	P	S	Nb	屈服 Y.S. ReL	抗拉 T.S. Rm	伸长 EL A200mm	
					%	%	%	%	%	%	%	N/mm2 (MPa)	%	
规范范围 SPECIFICATION					0	0	0	0	0	5	345	450	18	
HBM2543016	W25303613	W10×30 lbs/ft*12,000	1	4.304	21	26	111	25	11	6	485	590	24.0	
HBM2543017	W25303614	W10×30 lbs/ft*12,000	8	34.432	22	26	111	26	10	6	460	597	24.5	
TOTAL:			9	38.736										
注释 NOTE	L0=原始拉伸标距Original Gauge Length E.L=Percentage Elongation After Fracture A1(TL)=Tensile Test Tail Y.S.=Yield Strength T.S.=Tensile Strength													
备注 REMARK	表面及外形尺寸 SURFACE AND SIZE: 合格 QUALIFIED 无质量证明书专用章印记无效 INVALID WITHOUT SEAL ACCORDING TO EN 10204 3. 1													



尊敬的客户: 用前先要验证, 如有异议请保留实物并来函说明
FOR CUSTOMERS: TEST BEFORE USE, CLAIM FOR DISCREPANCIES WITH DEFAULT GOODS

本公司已通过 ISO9001 质量体系认证
APPROVED BY ISO9001