



MILL TEST CERTIFICATE

Customer: PRODALAM S.A.
Commodity: PRESTRESSED CONCRETE STRAND
Nominal Diameter: 15.24MM
Standard: ASTM A416/A416M-15
Production Licence No: XK 05-003-00098
Page No: 11/14
Inspection Date: FEB.5th,2022
Invoice No: PCLPY2301C
Container No. GLDU5176061



Mark on Coil	Coil No.	Dia MM	Section Area (mm ²)	Breaking Load (kN)	Tensile Strength MPA	1%Extension Yield Load (kN)	Yield Strength MPA	Elongation (%)	Modules of Elasticity GPA	Length Approx. Meter	Coil Weight KGS
B13	2302502-1	15.25	140.76	270.5	1932	250.9	1792	4.8	196.7	3036	3378
B13	2302506-1	15.26	140.76	273.1	1951	252.7	1805	5.3	195.6	3043	3386
B13	2302511-4	15.26	140.76	273.4	1953	250.0	1786	5.0	198.5	2435	2712
B13	2302513-5	15.26	140.76	273.4	1953	250.1	1786	4.8	196.5	2845	3166
B13	2302513-6	15.26	140.76	272.4	1946	246.5	1761	5.0	191.5	2926	3256
B13	2302514-4	15.26	140.76	270.7	1934	251.8	1799	4.9	197.5	2377	2648
B13	2302306-1	15.23	140.51	272.4	1946	253.7	1812	4.5	198.4	2635	2934
B13	2302306-2	15.23	140.51	272.2	1944	253.5	1811	4.6	198.2	2635	2934
B13	2302306-6	15.23	140.51	272.5	1946	250.4	1789	4.7	197.4	2863	3186

Filed by :Zhangchunting

Approved by : Shenyingsiang