




MILL TEST CERTIFICATE

Customer: PRODALAM S.A.
Commodity: PRESTRESSED CONCRETE STRAND
Nominal Diameter: 15.24MM
Standard: ASTM A416/A416M-15
Production Lisence No: XK 05-003-00098
Page No: 6/8
Inspection Date: MAR.5th,2023
Invoice No: PCLPID2302C
Container No. TRHU2463030



Mark on Coil	Coil No.	Dia MM	Section Area (mm ²)	Breaking Load (kN)	Tensile Strength MPA	1%Extension Yield Load (kN)	Yield Strength MPA	Elongation (%)	Modules of Elasticity GPA	Length Approx. Meter	Coil Weight KGS
J7	2302180-2	15.23	140.38	270.9	1935	244.4	1746	4.8	191.7	3043	3386
J7	2302180-4	15.23	140.38	268.8	1920	245.1	1751	5.0	192.5	2776	3090
J7	2302180-6	15.25	140.38	270.3	1931	246.1	1758	4.8	191.5	2957	3290
J7	2302181-3	15.23	140.51	271.0	1936	252.5	1804	4.9	196.5	2850	3172
J7	2302181-6	15.23	140.51	270.5	1932	245.8	1756	5.0	196.2	2653	2954
J7	2302181-7	15.23	140.51	272.3	1945	246.1	1758	4.9	195.0	2619	2916
J7	2302182-7	15.24	140.51	270.2	1930	249.9	1785	5.1	194.1	2662	2964
J7	2302183-7	15.26	140.89	270.2	1930	252.8	1806	5.0	197.2	2498	2782
J7	2302184-1	15.27	140.89	272.2	1944	256.2	1830	4.8	193.2	2857	3180

Filled by :Zhangchunting

Approved by : Shenyingsiang