



QINGDAO GLOBAL OVERSEAS IMP&EXP CO., LTD

Add: 4N Donghai Int'l Building, No.17 Huiquan Road, Qingdao, China

MILL TEST CERTIFICATE

Customer: PRODALAM S.A.
Commodity: PRESTRESSED CONCRETE STRAND
Nominal Diameter: 15.24 MM
Standard: ASTM A416/A416M-15
Production Liscence No: XK 05-003-00098
Page No: 2/12
Inspection Date: Jun.22th,2023
Invoice No: PCLPID2305C
Container No. MSDU2225881

Mark on Coil	Coil No.	Dia MM	Section Area (mm ²)	Breaking Load (kN)	Tensile Strength MPA	1%Extension Yield Load (kN)	Yield Strength MPA	Elongation (%)	Modules of Elasticity GPA	Length Approx. Meter	Coil Weight KGS
A2	2306547-1	15.26	140.89	273.8	1956	249.1	1779	5.2	197.0	2671	2974
A2	2306547-2	15.26	140.89	272.0	1943	251.0	1793	5.5	198.1	2670	2972
A2	2306547-4	15.26	140.89	272.7	1948	251.0	1793	5.2	198.1	2756	3068
A2	2306550-2	15.29	141.15	272.4	1946	249.7	1784	5.1	191.4	2661	2962
A2	2306550-3	15.29	141.15	273.5	1954	249.6	1783	5.4	196.3	2662	2964
A2	2306550-4	15.29	141.15	274.0	1957	248.2	1773	5.3	195.0	2662	2964
A2	2306550-7	15.29	141.15	273.4	1953	251.0	1793	5.2	194.8	2605	2900
A2	2306551-1	15.27	141.40	272.6	1947	246.5	1761	5.5	191.0	2662	2964
A2	2306551-4	15.27	141.40	275.3	1966	250.1	1786	5.1	198.6	2464	2744

Filled by :Zhangchunting

Approved by : Shenyingsiang