

**MILL TEST CERTIFICATE**

**Customer:** PRODALAM S.A.  
**Commodity:** PRESTRESSED CONCRETE STRAND  
**Nominal Diameter:** 15.24 MM  
**Standard:** ASTM A416/A416M-15  
**Production Licence No:** XK 05-003-00098  
**Page No:** 7/8  
**Inspection Date:** APR.14TH,2024  
**Invoice No:** PCLPY2402C  
**Container No.** FSCU7771800



Mark on Coil	Coil No.	Dia MM	Section Area (mm <sup>2</sup> )	Breaking Load (kN)	Tensile Strength MPA	1%Extension Yield Load (kN)	Yield Strength MPA	Elongation (%)	Modules of Elasticity GPA	Length Approx. Meter	Coil Weight KGS
B19	2404347-1	15.23	140.38	270.1	1929	249.8	1784	5.2	196.6	3032	3380
B19	2404347-3	15.23	140.38	271.1	1936	249.6	1783	5.1	198.8	2823	3148
B19	2404347-4	15.23	140.38	271.2	1937	250.5	1789	5.2	197.1	2823	3148
B19	2404347-5	15.23	140.38	270.3	1931	251.0	1793	5.1	198.1	2823	3148
B19	2404348-6	15.24	140.51	270.9	1935	252.7	1805	5.0	193.6	2941	3278
B19	2404352-6	15.26	140.51	272.0	1943	247.2	1766	5.1	195.3	2631	2934
B19	2404353-1	15.25	140.89	274.4	1960	252.3	1802	5.3	197.8	2438	2720
B19	2404353-2	15.25	140.89	273.9	1956	250.1	1786	5.4	195.2	2436	2718
B19	2404106-1	15.26	141.27	275.4	1967	256.9	1835	5.4	193.5	2856	3184

Quality objection: The buyer shall notify the seller in writing by email of any non-conformity of the quantity or quality of the subject matter within three months after arrival at the port. Where the buyer delays in giving notice beyond the prescribed time limit, the quantity or quality of the subject matter is deemed to be in conformity with the contract.

**Filed by :Zhangchunting**
**Approved by : Shenyangxiang**