



QINGDAO GLOBAL OVERSEAS IMP&EXP CO., LTD

Add: 4N Donghai Int'l Building, No.17 Huiquan Road, Qingdao, China

MILL TEST CERTIFICATE

Customer:

PRODALAM S.A.

Commodity:

PRESTRESSED CONCRETE STRAND

Nominal Diameter:

15.24 MM

Standard:

ASTM A416/A416M-15

Production Liscence No:

XK 05-003-00098

Page No:

7/12

Inspection Date:

Jun.22th,2023

Invoice No:

PCLPID2305C

Container No.

FBIU0116410

Mark on Coil	Coil No.	Dia MM	Section Area (mm ²)	Breaking Load (kN)	Tensile Strength MPA	1%Extension Yield Load (kN)	Yield Strength MPA	Elongation (%)	Modules of Elasticity GPA	Length Approx. Meter	Coil Weight KGS
A7	2306389-4	15.24	140.64	273.1	1951	253.1	1808	5.2	195.8	3045	3388
A7	2306389-5	15.24	140.64	271.6	1940	250.6	1790	5.4	199.4	3043	3386
A7	2306390-1	15.23	140.00	273.4	1953	258.7	1848	5.1	190.5	3031	3372
A7	2306392-1	15.24	139.62	272.9	1949	248.5	1775	5.1	195.4	3022	3362
A7	2306149-6	15.25	140.51	269.0	1921	251.4	1796	5.2	195.3	2523	2810
A7	2306150-6	15.25	140.25	271.4	1939	252.0	1800	5.0	196.1	3025	3366
A7	2306150-7	15.25	140.25	272.0	1943	251.0	1793	5.2	198.1	3016	3356
A7	2306151-6	15.26	140.13	272.9	1949	251.2	1794	5.4	196.7	3022	3362

Filled by :Zhangchunting

Approved by : Shenyingsiang